Installation Report for ASME Section IV
Cast Iron and Cast Aluminum Sectional Boilers

Note: ***This form must be filled in and mailed to your nearest ABSA Office. Steam boilers are to be hydrostatically tested to 310 kpa (45 psi) and Hot Water boilers to 1½ times the maximum allowable working pressure, after assembly.***

Cast Aluminum boilers can only be used in hot water service NOT steam service.

Manufacturer: _____

Boiler Model No.: _____

Serial No.: _____

CRN: _____

Provincial Identification No. (if any)**:** _____

Located at: _____

This is to certify that the above completed unit has been subjected to a hydrostatic test of _____ kpa as per the requirements of the ASME Code Section IV and that this test was satisfactory with no apparent defects observed.

Signed: _____

Company: _____

Date: _____

Edmonton Head Office
9410 20 Avenue NW
Edmonton, AB T6N 0A4

Grande Prairie District Office
#203, 10109 97 Avenue
Grande Prairie, AB T8V 0N5

Red Deer District Office
#304, 4406 Gaetz Avenue
Red Deer, AB T4N 3Z6

Calgary South Regional Office
100, 1111 57 Avenue NE
Calgary, AB T2E 9B2

Fort McMurray Office
103B, 9816 Hardin Street
Ft McMurray, AB T9H 4K3

The personal information collected on this form is for the purpose of collecting information for related to your installation report to comply with ASME Section IV for our records. This personal information collection is authorized by section 4(c) of the Protection of Privacy Act and will only be used for this purpose. If you have any questions about the collection of personal information, you may contact generalinq@absa.ca, or by mail to ABSA, 9410 20 Ave. NW, Edmonton, AB, T6N 0A4.