



Installation Report for ASME Section IV Cast Iron and Cast Aluminum Sectional Boilers

Note: *This form must be filled in and mailed to your nearest ABSA Office. Steam boilers are to be hydrostatically tested to 310 kpa (45 psi) and Hot Water boilers to 1½ times the maximum allowable working pressure, after assembly.*

Cast Aluminum boilers can only be used in hot water service NOT steam service.

Manufacturer: _____

Boiler Model No.: _____

Serial No.: _____

CRN: _____

Provincial Identification No. (if any): _____

Located at: _____

This is to certify that the above completed unit has been subjected to a hydrostatic test of _____ kpa as per the requirements of the ASME Code Section IV and that this test was satisfactory with no apparent defects observed.

Signed: _____

Company: _____

Date: _____

Edmonton Head Office
9410 20 Avenue NW
Edmonton, AB T6N 0A4

Grande Prairie District Office
#203, 10109 97 Avenue
Grande Prairie, AB T8V 0N5

Red Deer District Office
#304, 4406 Gaetz Avenue
Red Deer, AB T4N 3Z6

Calgary South Regional Office
380, 6715 8 Street NE
Calgary, AB T2E 7H7

Fort McMurray Office
103B, 9816 Hardin Street
Ft McMurray, AB T9H 4K3