

Information Bulletin IB19-014

December 10, 2019

ALERT
Emerson Automation Solutions Product Service Bulletin

This Information Bulletin replaces IB19-010 issued October 11, 2019 which is hereby withdrawn.

Emerson Automation Solutions has issued a Product Service Bulletin on July 22nd, 2019 and provided that Crosby “J-Series” Pressure Relief Valves (PRVs) may have reduced flow capacity potentially resulting in a safety hazard.

Product type series covered by the Emerson’s Bulletin are:

Brand: Crosby

Model Numbers: JBS-E, JLT JBS-E, JBSBP-E, JLT JBSBP-E, JBS, JLT JBS, JBSBP, JLT JBSBP

Office Sizes: D, E, G, H, J, K, L, M, N, P, Q, R, T and T2

Production Dates: Prior to July 22nd, 2019

The Emerson Automation Solutions Product Service Bulletin may be accessed at:
<https://www.emerson.com/documents/automation/crosby-j-series-product-service-bulletin-en-5888256.pdf>

For further information please contact Emerson's Impact Partner in western Canada, Spartan Controls:

Spartan Controls Ltd.
8403 – 51 Avenue NW,
Edmonton, Alberta T6E 5L9
Attention: Bernie Fedyniak
Email: fedyniak.bernie@spartancontrols.com

Those owners who may have the above PRVs installed on pressure equipment are asked to review the notice posted at Emerson’s website, contact Emerson for further information and take immediate action servicing valves as recommended by Emerson.

<original signed by>

Mike Poehlmann, P.L.(Eng.)
Administrator for Pressure Equipment
Chief Inspector, ABSA the pressure equipment safety authority

TYPE: ALERT	DESCRIPTION: Emerson Automation Solutions Product Service Bulletin	REGULATION: PESR
-------------	--	------------------