Information Bulletin No. IB25-005 WITHDRAWN 2025-06-25 **March 06, 2025**
REPLACED BY IB25-011

NOTIFICATION
CSA B52 Mechanical Refrigeration Code, 2023 Edition in Force with Amendment

The latest revision of Information Bulletin No. IB24-002 serves as a reference to the current in-force editions of the codes, standards, and bodies of rules declared in force by section 6 of the Pressure Equipment Safety Regulation (PESR):

The 2023 edition of CSA B52 Mechanical refrigeration code is declared in force, with an amendment that clause 6.3 b) of the 2018 edition be declared mandatory.

CSA B52:18 clause 6.3 Class T machinery rooms states:

> *b) The machinery room shall have at least one exit door that opens directly to the outer air. Other exits communicating with the building shall be permitted but shall be through a vestibule equipped with approved self-closing, tight-fitting fire doors.*

This clause shall remain in force and therefore be a requirement with respect to machinery rooms for flammable refrigerants classified 2L, 2 and 3 as identified CSA B52:23 clause 6.3.

<original signed by>

Djordje Srnic, M.Sc., P.Eng.
Administrator, Province of Alberta Pressure Equipment Safety
Chief Inspector, ABSA the pressure equipment safety authority